

DRAFT PERMIT No. ST000042200590

SEWAGE TREATMENT

FACILITY No. S-20931

**DRAFT PERMIT TO CONSTRUCT
PROVISIONS AND CONDITIONS**

This permit is issued subject to the following provisions and conditions.

- 1) That the recipient of the permit is responsible that the project receive supervision and inspection by competent and qualified personnel.
- 2) That construction of all phases of the project will be started within one year of the date of approval or the phases not under construction will be resubmitted for approval as a new project.
- 3) That no significant information necessary for a proper evaluation of the project has been omitted or no invalid information has been presented in applying for the permit.
- 4) That the Oklahoma Department of Environmental Quality shall be kept informed of occurrences which may affect the eventual performance of the works or that will unduly delay the progress of the project.
- 5) That the issuing of this permit does not relieve the responsible parties from any damage which may accrue as the result of the location and operation of the plant in this area.
- 6) That the recipient of the permit is responsible for the continued operation and maintenance of these facilities in accordance with the rules and regulations adopted by the Environmental Quality Board and that this Department will be notified in writing of any sale or transfer of ownership of the facilities.
- 7) That these facilities are approved for an average hydraulic loading of 6,600 gallons/day or an organic load of 11 pounds of BOD₅/day. Before additional loading is connected to the system, plans for suitable enlargement of the facilities shall be submitted to the Oklahoma Department of Environmental Quality for approval.
- 8) That the permittee is responsible for complying fully with NPDES permit provisions and submitting a permit renewal application 180 days prior to permit expiration.
- 9) That any deviations from approved plans or specifications affecting capacity, flow or operation of units must be approved by the Department before any such deviations are made in the construction of this project.
- 10) That any notations or changes recorded on the official approved set of plans and specifications in the Oklahoma Department of Environmental Quality files shall be a part of the plans as approved.



SCOTT A. THOMPSON
Executive Director

OKLAHOMA DEPARTMENT OF ENVIRONMENTAL QUALITY

KEVIN STITT
Governor

DRAFT PERMIT No. ST000042200590

SEWAGE TREATMENT

FACILITY No. S-20931

DRAFT PERMIT TO CONSTRUCT

- 11) As-built plans of this project shall be placed on file with this Department within two months of the completion of the work or a certification by the engineer shall be submitted certifying that no changes have been made in the work as approved.
- 12) The issuance of this permit does not relieve the responsible parties of any obligations or liabilities which the permittee may be under pursuant to prior enforcement action taken by the Department.

Failure to appeal the conditions of this permit in writing within 30 days from the date of issue will constitute acceptance of the permit and all conditions and provisions.

A handwritten signature in black ink that reads 'Rocky Chen'. The signature is written in a cursive, slightly slanted style.

AS

Rocky Chen, P.E., Engineering Manager, Construction Permit Section
Water Quality Division

